



**Decospan nv**  
**Lageweg 33**  
**B-8930 Menen**

**Your message**

**Your reference**

**our reference**

**Gent**

Jw/1634

2021-06-29

## Evaluation of emission to indoor air

---

Dear,

On the product Bill our sample reference T2107613, delivered by Decospan, we analysed the emission profile and evaluated the results mentioned in analysis report A21.02126.01 to the criteria mentioned in some national legislations regarding indoor air quality.

For determination and characterisation the following methods are used:

- **EN 16516: Emission of volatile compounds (chamber method)**
- **ISO 16000 parts 3: Determination of aldehydes after emission**

Based on the outcome of the emission measurement after 3 and 28 days on the product Bill, our sample reference T2107613, we can conclude that the product range Twelve collection fulfils to:

Regulation or protocol	Conclusion
French VOC regulation	A+
French CMR components	Pass
	
Chemsverbot (formaldehyde)	pass
EN 14342	Formaldehyde class E1

We hope having been helpful with this information.

Yours sincerely,

PhD. Jo Wynendaele

Consultant Floor and Wall coverings

